

Uploading the project to the Neets Control - EU via the programming board (RS-232) worked at home, but not at the customer – why is that?

Regarding products:



307-0001, 307-0002, 307-0004: Control systems and programming board

Uploading the project to the Neets Control - EU via the programming board (RS-232) worked at home, but not at the customer – why is that?

When you upload a project to a Neets Control – EU via RS-232, you always have to remember to disconnect the unit connected to Rx1, Tx1 on the back side. (worst case the RS-232 port in either the computer or the connected unit can burn).

Best Regards

Neets